

# EMPOWER ENERGY

## ELEKTROBANK 14 – VIC EMERGENCY BACKSTOP GUIDE

### NOTICE

DNSPs in Victoria are requiring that new inverters being installed are capable of an “Emergency Backstop” functionality. This document describes the process for registering and testing the Emergency backstop capability on the ElektroBank 14 in Victoria.

See [Victoria's emergency backstop mechanism for solar](#) and [Industry guidance](#) for more information.

### MODELS

ElektroBank 14


### APPLICABILITY

As required by DNSPs in Victoria.

### PROCEDURE

#### 1 CONFIGURATION (EMPOWER INSTALLATION WIZARD)

After physical installation of the ElektroBank 14 and during configuration via the installation wizard, there will be a field for the NMI number. Once entered, the wizard will automatically pre-fill the DNSP field



The screenshot shows the 'Installation Configuration and Verification' window. At the top, there's a progress bar with three steps: 'Site Details' (active), 'Verification', and 'Summary'. Below this, a list of configuration items is shown with green checkmarks: 'National Meter Identification', 'Site Address', 'Owner Account', 'DNSP and Phase', 'Backup Connection', 'AS4777 Grid Configuration', 'PV Configuration', and 'Battery Modules'. The 'National Meter Identification' step is expanded, showing a text input field labeled 'Type the NMI here' with a red arrow pointing to it. Below this field is a 'Continue' button. The 'DNSP and Phase' step is also expanded, showing a text input field with the text 'The DNSP will be filled automatically' inside, which is highlighted with a red box.

Figure 1: Site Details page of Installation Wizard showing automatic selection of DNSP by entering the NMI

## 2 REGISTRATION OF ELEKTROBANK 14 TO THE DNSP (EMPOWER INSTALLATION WIZARD)

Citipower, Powercor & United Energy and Ausnet

In the Installation Wizard, complete all the **Verification** steps to get to the Registration step. Click Register to trigger the Emergency Backstop Registration as shown in **Figure 2**. This may take up to 10 minutes.




Figure 2: DNSP Registration step in Installation Wizard




Figure 3: DNSP Capability Test showing tick boxes

### Jemena

Jemena does not offer “in-band” registration, so it requires Empower to take manual steps. Thus, for all Jemena installations, please contact Empower at the start of the installation by calling 02 9845 8835 and supply the serial number of the ElektroBank 14, so we can prepare for registration.

After completing all the Verification steps, please call Empower again to request an LFDI number. Empower will email or text you the LFDI number, which can then be inputted into Jemena’s online portal.

Jemena use [myservices electricity distribution portal \(EDP\)](#) and provide [further instruction & video](#).

## 3 RUNNING THE CAPABILITY TEST (DNSP’S PORTAL)

Citipower, Powercor & United Energy and Ausnet

To finalise testing of Emergency Backstop, the installer must log into the portal of the DNSP to verify **registration** of the ElektroBank 14 was successful and then **Run Test** to complete the Communication Capability Test.

- Citipower & Powercor use [eConnect](#) and provide [further instruction & video](#).
- United Energy use [myEnergy](#) and provide [further instruction & video](#).
- AusNet use [AusNet portal](#) and provide [further instruction](#).

## Jemena

Jemena does not offer a capability test in their portal. Instead, the installer must submit the “Commission my CSIP-Aus Inverter” application and Jemena will perform the commissioning tests over the next 7 to 10 days.

Jemena use [myservices electricity distribution portal \(EDP\)](#) and provide [further instruction](#) & [video](#).

## 4 FINALISING THE COMMISSIONING (EMPOWER INSTALLATION WIZARD)



### Critical

**DO NOT** tick both boxes in Figure 3 (in the installation wizard) until the capability test has been completed and verified on the respective DNSP’s portal. Proceeding to the Summary page (in the installation wizard) without having completed the capability test will change the mode of the ElektroBank 14, and potentially prevent the capability test from completing successfully.

## Citipower, Powercor & United Energy and Ausnet

Once the Emergency Backstop capability test has completed successfully, the installer should complete the rest of the Empower Installation Wizard to finalise commissioning. The installation wizard will prompt the installer to confirm the capability test was started and successful (**Figure 3**) before allowing them to continue.

## Jemena

Jemena does not offer a real-time capability test in their portal. Once the application is submitted to, they will perform the capability test at their leisure (it may up to 10 days). When the installer receives notice that the test was successful, then the installer should log back into the Installation Wizard to confirm the capability test was completed (**Figure 3**).

## REFERENCE LINKS

### CITIPOWER & POWERCOR:

- [VIC Backstop for Solar Installers](#)
- [Emergency backstop for minimum system load events](#)
- Video: [Completing the DER capability test | emergency backstop guide for solar installers | Citipower](#)

### UNITED ENERGY:

- [VIC Backstop for Solar Installers](#)
- [Emergency backstop for minimum system load events](#)
- [Completing the DER capability test | emergency backstop guide for solar installers | United Energy](#)

### AUSNET:

- [Solar emergency backstop](#)
- [Commissioning Checklist for Solar Emergency Backstop](#)
- [Solar emergency backstop guide](#)

## JEMENA:

- [Emergency Backstop Mechanism](#)
- Video: [Emergency Backstop Mechanism, Jemena Electricity Portal Walk-through](#)
- [Solar and Other technologies](#)
  - [More useful links](#)
- [Jemena's Emergency Backstop Webinar for solar installers](#)
- [Overview of process](#)

## QUESTIONS?

Please contact the DNSP first:

- **Citipower & Powercor:** [newenergyservices@powercor.com.au](mailto:newenergyservices@powercor.com.au) or on 1800 772 940 (8am-4pm, Monday to Friday).
- **United Energy:** [newenergyservices@ue.com.au](mailto:newenergyservices@ue.com.au) or on 1800 772 940 (8am-4pm, Monday to Friday).
- **AusNet:** [solarbackstop@ausnetservices.com.au](mailto:solarbackstop@ausnetservices.com.au) or on 1300 360 795
- **Jemena:** None provided. Call their general enquiry on 1300 131 871

If the issue cannot be resolved, please Empower at 02 9845 8835 or [support@elektrobank.com.au](mailto:support@elektrobank.com.au).